

Consultee Comment for planning application 21/03169/CLUP

Application Number	<input type="text" value="21/03169/CLUP"/>
Location	<input type="text" value="Moorhouse Church Lane Wendlebury OX25 2PN"/>
Proposal	<input type="text" value="Certificate of Lawfulness of Proposed Development for the erection of a single storey side and rear extension, replacement of a flat roof with a pitched roof, a single storey rear extension and porch extension"/>
Case Officer	<input type="text" value="Emma Whitley"/>
Organisation	<input type="text" value="Building Control (CDC)"/>
Name	<input type="text"/>
Address	<input type="text" value="Building Control Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="The development would require a building regulations application. Please note that a build-over agreement with the relevant sewerage undertaker will be required if building over or within 3 metres of a public sewer, or within 1 metre of a public lateral drain."/>
Received Date	<input type="text" value="10/11/2021 10:11:30"/>
Attachments	