



DO NOT SCALE

- NOTES:
1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED.
 2. INTERCEPTOR TO BE FITTED WITH SOLAR POWERED GSM ALARM SYSTEM, FOR DETAILS REFER TO CONDOR RECOMMENDATIONS.
 3. INTERCEPTOR TO BE CONDOR FULL RETENTION TYPE CNS40S OR SIMILAR, FOR MAXIMUM CATCHMENT AREA OF 2222m².
 4. INSTALLATION OF PETROL INTERCEPTORS TO BE IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS.
 5. FOR DETAILS OF VENTING REFER TO DRAWING 1903/SD/021. VENTING REQUIREMENTS TO BE IN ACCORDANCE WITH BS8301 AND NATIONAL BUILDING SPECIFICATIONS R12/781

REV	DATE	BY	DESCRIPTION	CHK	APP
B		ACK	TELEMETRY DETAILS ADDED	JM	JM
A	12/03/08	ACK	FIRST ISSUE	JM	JM

DRAWING STATUS:
FOR INFORMATION ONLY



Mountbatten House, Basing View, Basingstoke, Hampshire RG21 4HU
Tel: +44 (0)1256 318800 Fax: +44 (0)1256 318700
<http://www.wspgroup.com>

CLIENT: COUNTRYSIDE PROPERTIES

ARCHITECT:

PROJECT: SOUTH WEST BICESTER
BICESTER, OXFORDSHIRE

TITLE: HOWES LANE ROUNDABOUT
OFFSITE WORKS
PETROL INTERCEPTOR DETAIL

SCALE @ A3	CHECKED:	APPROVED:
N.T.S.	JM	JM
CAD FILE:	DESIGN DRAWN:	DATE:
1903-SD-035.DWG	ACK	March 08
PROJECT NO:	DRAWING NO:	REV:
11011903	1903/SD/035	B