

THIRD PARTY DRAWING REFERENCE		READ IN CONJUNCTION WITH THE FOLLOWING:		NOTES				Hopkins Mechanical & Electrical Engineers		
Architect L-OM-1006 GF	- Proposed Plan - HFSK	Drawing Number E10241-001	Drawing Title ELECTRICAL SERVICES STANDARD SYMBOLS AND ABBREVIATIONS	A CASCADE EDGE (DALI CONTROL GEAR AS STANDARD) - 1750IM LED	G PENNA (LOUVRE) (DIRECT:INDIRECT RATIO - 80:20) - 1X28W T5	KI MIRAGE LED COMFORT + IP64 COVER - 2000IM LED	<u>R</u> TRIMPAK - 1X28W T5 <u>R1</u> TRIMPAK - 1X35W T5		J & B Hopkins Ltd Concorde House	KIER
Structural		-		A1 CASCADE EDGE (DALI CONTROL GEAR AS STANDARD) - 35001M LED	G1 PENNA (LOUVRE) (DIRECT:INDIRECT RATIO - 80:20) - 1X35W T5	M HYGIENE - 4X24W T5	R2 TRIMPAK - 2X28W T5			HEYFORD PARK FREE SCHOOL OXFORD
Consultant		-		B TEGAN OFFICE - 4100IM LED DUO2 (WITH MICRO PRISM CENTRE	ECHO 280 LED + PART METALISED REFRACTOR - 4000IM LED	NTEGAN AREA - 1950IM LEDN1TEGAN AREA - 4100IM LED	R3 TRIMPAK - 2X35W T5 S ACF DURALITE - 2X35W T5		www.jbhopkins.co.uk	DRAWING TITLE SPORTS HALL GROUND FLOOR LEVEL
Others		-		OPTIC) - 2X20W T5		P STILETTO LED - 2700IM LED	KOLO - 2300IM LED	P1 ISSUED FOR APPROVAL/COMMENT		LIGHTING SERVICES LAYOUT
				C1 DUO2 (WITH MICRO PRISM CENTRE OPTIC) - 3X20W T5 F ORIAS SURFACE (LOUVRE) - 2X35W T	5 MIRAGE LED COMFORT - 2000IM LED MIRAGE LED COMFORT + IP64 COVER - 1100IM LED	PI STILETTO LED - 4200IM LED P2 STILETTO LED - 7000IM LED	CENTURION 350 LED - 1100IM LED	REF REVISION BY/DATE	FOR APPROVAL	DRAWING NUMBER E10241 SH - 500 P1



