

PROJECT : Heyford free School

BUILDING 583 (Sports Centre)

PLANNING REFERENCE 13/00343/F

PLANNING CONDITION : 18

Noise Emittance :

Enclosed for reference :

- (i) External Plant Specifications
- (ii) Initial Noise Survey



The residential properties on Eady Road are approximately 260m from the proposed plant location. Using hemispherical propagation calculations, the combined noise emissions of the plant will be approximately 20 dB.

This is considerably lower than the proposed noise limits and existing background noise levels measured in the previous noise survey.

Therefore there will be no impact on the Eady Road Noise levels from the external plant on the Sports Building.