

Consultee Comment for planning application 23/00207/DISC

Application Number	23/00207/DISC
Location	Proposed Himley Village North West Bicester Middleton Stoney Road Bicester
Proposal	Discharge of Conditions 7 (site wide Phasing Plan), 11 (full surface Water Drainage Scheme) and 10 (Site Wide Biodiversity Strategy) of 14/02121/OUT (as amended by 22/03492/NMA)
Case Officer	Suzanne Taylor
Organisation	Land Drainage (CDC)
Name	Tony Brummell
Address	Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA
Type of Comment	Comment
Type	
Comments	Refer to Oxfordshire County Council as Lead Local Flood Authority for substantive comments. The drainage strategy outline plan Site Wide Drainage Strategy AMENDED 27141-HYD-XX-XX-TN-C-0005 P01" is incorrect. It shows the drainage at the south-east corner of the side crossing Middleton Stoney Road and discharging to the south. It does not - it discharges into the ditch on the south side of Middleton Road and flows eastwards. I have made the LLFA aware.
Received Date	12/11/2023 08:48:17
Attachments	