

Consultee Comment for planning application 23/00207/DISC

Application Number	<input type="text" value="23/00207/DISC"/>
Location	<input type="text" value="Proposed Himley Village North West Bicester Middleton Stoney Road Bicester"/>
Proposal	<input type="text" value="Discharge of Conditions 7 (site wide Phasing Plan), 10 (Biodiversity Strategy) and 11 (full surface Water Drainage Scheme) of 22/03492/NMA"/>
Case Officer	<input type="text" value="Suzanne Taylor"/>
Organisation	<input type="text" value="CDC - Land Drainage"/>
Name	<input type="text" value="Tony Brummell"/>
Address	<input type="text" value="Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="No comments in principle subject to any comments the LLFA has regarding detail. For information, note that the ditch which flows eastwards on the northern side of the B4030 outside the application site is culverted to cross the Middleton Stoney Road/Howes Lane junction diagonally. Flows are then conveyed in a ditch on the south side of Middleton Road before discharging into the upper reaches of the Pingle Stream."/>
Received Date	<input type="text" value="06/02/2023 16:42:28"/>
Attachments	