

Lynne Baldwin

---

**From:** Speakman, Glenn - Communities <Glenn.Speakman@Oxfordshire.gov.uk>  
**Sent:** 12 November 2020 12:00  
**To:** Linda Griffiths; DC Support  
**Subject:** 20/02813/DISC - Land South West Of Bicester Adjoining Oxford Road And Middleton Stoney Road Bicester - Partial discharge of condition 34 (service trenches, pipe runs, drains, earth movement) of 06/00967/OUT - (For Parcels KMF & G by Linden Homes)

Hi Linda,

We do not object to the discharge of condition 34 but have the following comment:

The services are currently shown going through visitor parking bays in the carriageway, services will require dropping in this section to ensure they are outside of the carriageway construction.

Regards,

Glenn Speakman MSc  
Assistant Transport Planner (Cherwell, West Oxfordshire and Oxford City)  
Oxfordshire County Council  
Mobile: 07768331664

This email, including attachments, may contain confidential information. If you have received it in error, please notify the sender by reply and delete it immediately. Views expressed by the sender may not be those of Oxfordshire County Council. Council emails are subject to the Freedom of Information Act 2000. [email disclaimer](#). For information about how Oxfordshire County Council manages your personal information please see our [Privacy Notice](#).