

Rachel Tibbetts

From: BCTAdmin@thameswater.co.uk
Sent: 25 September 2023 16:00
To: Planning
Subject: 3rd Party Planning Application - 23/02471/F

CAUTION: This email originated from outside of the Council. Do not click links or open attachments unless you recognise the sender and know the content is safe.

Cherwell District Council Our DTS Ref: 46691
Planning & Development Services Your Ref: 23/02471/F
Bodicote House
Bodicote, Banbury
Oxon
OX15 4AA

25 September 2023

Dear Sir/Madam

Re: OS Parcel 0622, South Of Jersey Cottages , East Of Heyford Road, KIDLINGTON, OXFORDSHIRE, OX5 3HU

Waste Comments

There are public sewers crossing or close to your development. If you're planning significant work near our sewers, it's important that you minimize the risk of damage. We'll need to check that your development doesn't limit repair or maintenance activities, or inhibit the services we provide in any other way. The applicant is advised to read our guide working near or diverting our pipes. <https://www.thameswater.co.uk/developers/larger-scale-developments/planning-your-development/working-near-our-pipes>

With regard to SURFACE WATER drainage, Thames Water would advise that if the developer follows the sequential approach to the disposal of surface water we would have no objection. Management of surface water from new developments should follow guidance under sections 167 & 168 in the National Planning Policy Framework. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. Should you require further information please refer to our website.

<https://www.thameswater.co.uk/developers/larger-scale-developments/planning-your-development/working-near-our-pipes>

We would expect the developer to demonstrate what measures will be undertaken to minimise groundwater discharges into the public sewer. Groundwater discharges typically result from construction site dewatering, deep excavations, basement infiltration, borehole installation, testing and site remediation. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. Should the Local Planning Authority be minded to approve the planning application, Thames Water would like the following informative attached to the planning permission: "A Groundwater Risk Management Permit from Thames Water will be required for discharging groundwater into a public sewer. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 020 3577 9483 or by emailing trade.effluent@thameswater.co.uk . Application forms should be completed on line via www.thameswater.co.uk. Please refer to the Wholesale; Business customers; Groundwater discharges section.

Thames Water would advise that with regard to WASTE WATER NETWORK and SEWAGE TREATMENT WORKS infrastructure capacity, we would not have any objection to the above planning application, based on the

information provided.

Water Comments

If you are planning on using mains water for construction purposes, it's important you let Thames Water know before you start using it, to avoid potential fines for improper usage. More information and how to apply can be found online at thameswater.co.uk/buildingwater.

On the basis of information provided, Thames Water would advise that with regard to water network and water treatment infrastructure capacity, we would not have any objection to the above planning application. Thames Water recommends the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Yours faithfully
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ
Tel:020 3577 9998
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk
Visit us online www.thameswater.co.uk , follow us on twitter www.twitter.com/thameswater or find us on www.facebook.com/thameswater. We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.