

From: Tony Brummell <Tony.Brummell@Cherwell-DC.gov.uk>
Sent: 03 February 2022 15:50
To: Gemma Magnuson <Gemma.Magnuson@cherwell-dc.gov.uk>
Subject: RE: 22/00032/F

Gemma

I agree with the applicant's comments. From my knowledge of the local superficial geology, a discharge to ground is very unlikely to be successful.

For the applicant's information an Environmental Permit for the discharge to a ditch or watercourse would only be needed if the daily effluent volume exceeded 5,000 litres per day. That would be equivalent to about 60 persons occupying standard yurts so will not be relevant to this application. However, if the Bio-disc effluent should cause pollution, that would not preclude action being taken under environmental legislation. Provided the Bio-disc is maintained and serviced in accordance with the manufacturer's/installer's instruction there should be no problems.

Tony Brummell CEng FICE FCIWEM MCIHT
Building Control and Flood Risk Manager

Cherwell Building Control Service
Environment and Place Directorate
Cherwell District Council

Direct Dial: 01295 221909
tony.brummell@cherwell-dc.gov.uk
www.cherwell.gov.uk

www.facebook.com/cherwelldistrictcouncil

Twitter @Cherwellcouncil

Coronavirus (COVID-19): The Building Control service has been set up to work remotely. Customers are asked to contact the Building Control team at building.control@cherwell-dc.gov.uk or to use the Council's customer contact form at [Contact Us](#) . For the latest information on Building Control please visit www.cherwell-dc.gov.uk