

Technical Submittal Transmittal Sheet

QT 39	Rev. 00		
Issue date: 23/05/2017	Page 1 of 2		

Document Ref: Submittal No. 49 Submittal Subject: Foul Pumping Station

To: Tower Eight

Name of Reviewer: David Wallace

Tel: +44 (0)20 7323 6809

Email: david.wallace@towereight.com

From: Elliott Building & Civil Engineering UK Ltd

Name of Issuer: David Givney

Tel: 07367 881423

Email: d.givney@elliottgroupuk.com

Project Ref:	Holiday Inn Express - Bicester	Revision	0
Contract Name:	Hotel Bicester Gateway	Date:	01/11/19

We formally request your approval of the proposed product, and issue of an EAI for same:

Items: We are requesting an instruction to remove the existing foul tank and replace with a fit for purpose adoptable pumping station & tank in accordance with Thames Waters requirements.

Description: Elliott's have procured a foul pumping specialist subcontractor (APS) who are familiar with Thames Water requirements. APS have issued a proposal for a revised foul pumping system which will satisfy the latest TW requirements. This proposal consists of a replacement foul tank and a significant amount of additional works such as building an inlet, valve & pumping chambers, supplying additional power from the new substation along with other associated works. If all parties are satisfied with the proposal, please issue an instruction to proceed so we can progress the works.

Supplier/Manufacturer: All Pump Solutions

Attachments:

- All Pump Solutions foul pumping station proposal
- NORR Proposed Site Plan
- MCA drawing showing electrical duct run
- C1005 Shows an 8.5m long vehicle access route to enclosure.
- C1006 Shows an 8.5m long vehicle egress route to enclosure.
- C1005A Shows an 9.5m long vehicle access route to enclosure.
- C1006A Shows an 9.5m long vehicle egress route to enclosure.

SUBMITTAL RETURN (To be completed by Submittal Reviewer):



Technical Submittal Transmittal Sheet

QT 39	Rev. 00	
Issue date: 23/05/2017	Page 2 of 2	

A Accepted	B Accepted With Cor	nments C Re-Subn	nit
Comments:			
Print Name:		Date:	

NOTE:

This Contractors Design Proposal is submitted in accordance with the JCT D&B 2016 Schedule 1 Contract Conditions, maximum 14 day review and approval period.