

Vertase FLI Limited
1 Middle Bridge Business Park
Bristol Road
Portishead, Bristol
BS20 6PN

FAO Gavin Moore
19 August 2011


Dear Gavin Moore

Test Report Number **119194**
Your Project Reference **1246 DOR**

Please find enclosed the results of analysis for the samples received 15 August 2011.

If you require any further assistance, please do not hesitate to contact the Customer Services team.

Yours sincerely



Authorised Signatory

Darrell Hall Director
 Phil Hellier Director
 Keith Jones Technical Manager
 John Crawford Quality Manager
 Malcolm Avis Director



2183



Test Report 119194 Cover Sheet

Login Batch No			119194
Chemtest LIMS ID			AG35541
Sample ID			
Sample Description			Gasket
SOP↓	Determinand↓	CAS No↓	
2185	Actinolite	77536664	Not detected
	Amosite	12172735	Not detected
	Anthophyllite	77536675	Not detected
	Chrysotile	12001295	Detected
	Crocidolite	12001284	Not detected
	Tremolite	77536686	Not detected
	Material		gasket

All tests undertaken between 15-Aug-2011 and 15-Aug-2011

Signed

Albert Vella
Senior Environmental Surveyor



2183

Notes to accompany report:

- The in-house procedure SOP 2185 is in accordance with the requirements of Appendix 2 of the Analyst Guide (HSG248)
- The results relate only to the items tested as supplied by the client
- Comments and interpretations are not UKAS accredited
- Amosite is alternatively termed 'brown asbestos'
- Chrysotile is alternatively termed 'white asbestos'
- Crocidolite is alternatively termed 'blue asbestos'
- Samples associated with asbestos in building surveys are retained for sixmonths (HSG 264 refers)
- Comments or interpretations are beyond the scope of UKAS accreditation

Vertase FLI Limited
1 Middle Bridge Business Park
Bristol Road
Portishead, Bristol
BS20 6PN

FAO Jonathan Lewis
09 September 2011


Dear Jonathan Lewis

Test Report Number **119557**
Your Project Reference **1246 DOR**

Please find enclosed the results of analysis for the samples received 7 September 2011.

If you require any further assistance, please do not hesitate to contact the Customer Services team.

Yours sincerely



Authorised Signatory

- | | | |
|-------------------------------------|---------------|-------------------|
| <input checked="" type="checkbox"/> | Darrell Hall | Director |
| <input type="checkbox"/> | Phil Hellier | Director |
| <input type="checkbox"/> | Keith Jones | Technical Manager |
| <input type="checkbox"/> | John Crawford | Quality Manager |
| <input type="checkbox"/> | Malcolm Avis | Director |



2183



Test Report 119557 Cover Sheet

LABORATORY TEST REPORT

Results of analysis of 2 samples
received 7 September 2011

Report Date
09 September 2011

FAO Jonathan Lewis

1246 DOR

Login Batch No		119557		
Chemtest LIMS ID		AG43610	AG43611	
Sample ID		Gasket	Gasket	
Sample Description		POL16	POL17	
SOP↓	Determinand↓	CAS No↓		
2185	Actinolite		Not detected	Not detected
	Amosite		Not detected	Not detected
	Anthophyllite		Not detected	Not detected
	Chrysotile		Not detected	Detected
	Crocidolite		Not detected	Not detected
	Tremolite		Not detected	Not detected
	Material		gasket	gasket

All tests undertaken between 07-Sep-2011 and 7-Sep-2011

Signed

Albert Vella
Senior Environmental Surveyor



2183

Notes to accompany report:

- The in-house procedure SOP 2185 is in accordance with the requirements of Appendix 2 of the Analyst Guide (HSG248)
- The results relate only to the items tested as supplied by the client
- Comments and interpretations are not UKAS accredited
- Amosite is alternatively termed 'brown asbestos'
- Chrysotile is alternatively termed 'white asbestos'
- Crocidolite is alternatively termed 'blue asbestos'
- Samples associated with asbestos in building surveys are retained for sixmonths (HSG 264 refers)
- Comments or interpretations are beyond the scope of UKAS accreditation