

Consultee Comment for planning application 19/01387/F

Application Number	<input type="text" value="19/01387/F"/>
Location	<input type="text" value="Muddle Barn Farm Colony Road Sibford Gower Banbury OX15 5RY"/>
Proposal	<input type="text" value="Variation of Condition 2 (plans) of 16/01563/F - alterations to the design of the replacement dwelling, the construction of a replacement outbuilding, provision of a new 2m high wall and demolition of two bays of a stable building"/>
Case Officer	<input type="text" value="Bob Neville"/>
Organisation Name	<input type="text" value=""/>
Name	<input type="text" value="Building Control (CDC)"/>
Address	<input type="text" value="Building Control Surveyors"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text" value=""/>
Comments	<input type="text" value="Other than ensuring that the track to the proposed dwelling is adequate for B5 Fire Rescue Vehicle access, there do not appear to be any issues with the layout."/>
Received Date	<input type="text" value="16/08/2019 11:08:41"/>
Attachments	