

## Bernadette Owens

---

**From:** Bill Bailey <wb@bjh.co.uk>  
**Sent:** 24 February 2020 16:03  
**To:** Littler, Adam - Communities  
**Cc:** Bernadette Owens; 'emma.lancaster@quod.com'; Kelvin Pearce; James Griffiths  
**Subject:** EMAIL 1 OF 4 - RE: Bicester Catalyst  
**Attachments:** S1358 - Ext - 46B - Concept SW Drainage Scheme.pdf

### EMAIL 1 OF 4

S1358/200224em/WB/LDD



**Adam Littler**  
**Oxfordshire County Council**

Dear Adam

**Re: BICESTER CATALYST, WENDLEBURY ROAD, BICESTER**

You will have seen that all the river modelling has been sent to the Environment Agency; they are reviewing the data and I am hoping to get the removal of their Objection 2 shortly.

In the meantime, I attach (in 4 emails) the following further information to confirm that the removal of the existing ditch will not present any problems with regard to surface water flows:

- BJH Updated Plans:
  - S1358-Ext-46B – Concept SW Drainage Scheme
  - S1358-Ext-34B – Surface Water Drainage Strategy and Layout
  - S1358-Ext-54 – Section 278 Works Drainage Layout
  - S1358-Ext-52 – Hedgerow Ditch Removal - Existing Flow Routes
  - S1358-Ext-53 – Hedgerow Ditch Removal – Proposed Flow Routes.
- Section 278 Drainage Design
- Assessment of Ditch Capacity

I trust the above demonstrates that the removal of the existing ditch will not present a problem.

Please note that there are ongoing discussions with OCC Highways relating to the roundabout and cycle paths so there could be some small changes, however, these changes will not affect the fundamental of our Surface Water Drainage approach.

I trust the above will enable you to review and remove your planning objections shortly.

Any queries at all please call me.

Kind regards.

Yours sincerely



W. Bailey  
Bailey Johnson Hayes

Suite 4, Phoenix House  
63 Campfield Road  
St. Albans, AL1 5FL

Tel: 01727 841172  
Fax: 01727 841085  
Mob: 07836 726299  
wb@bjh.co.uk  
www.bjh.co.uk

This email and any files transmitted with it are confidential and intended solely for the use of the addressee. If you have received this email in error please notify the sender. Finally, the recipient should check this email and any attachments for the presence of viruses as we accept no liability for any damage caused by any virus transmitted by this email.

---

**From:** Littler, Adam - Communities [mailto:Adam.Littler@Oxfordshire.gov.uk]  
**Sent:** 13 February 2020 13:08  
**To:** Bill Bailey  
**Cc:** Bernadette Owens  
**Subject:** Bicester Catalyst

Dear Bill,

I hope you are well.

How are we progressing with modelling of removal of the “ditch” and development of the outline plans for the site drainage?

Many thanks,

Adam.

**Drainage Engineer  
Oxfordshire County Council  
County Hall  
New Road  
Oxford  
OX1 1ND**

This email, including attachments, may contain confidential information. If you have received it in error, please notify the sender by reply and delete it immediately. Views expressed by the sender may not be those of Oxfordshire County Council. Council emails are subject to the Freedom of Information Act 2000. [email](#)

[disclaimer](#). For information about how Oxfordshire County Council manages your personal information please see our [Privacy Notice](#).