

## Rachel Tibbetts

---

**From:** BCTAdmin@thameswater.co.uk  
**Sent:** 03 December 2019 10:06  
**To:** Planning  
**Subject:** 3rd Party Planning Application - 19/02350/OUT

Cherwell District Council  
Planning & Development Services  
Bodicote House  
Bodicote, Banbury  
Oxon  
OX15 4AA

Our DTS Ref: 63604  
Your Ref: 19/02350/OUT

3 December 2019

Dear Sir/Madam

Re: DEERFIELDS FARM, CANAL LANE, BODICOTE, BANBURY, OXFORDSHIRE , OX15 4AD

### Waste Comments

With the information provided, Thames Water has been unable to determine the waste water infrastructure needs of this application. Thames Water has contacted the developer in an attempt to obtain this information and agree a position for FOUL WATER drainage, but have been unable to do so in the time available and as such, Thames Water request that the following condition be added to any planning permission. "No properties shall be occupied until confirmation has been provided that either:- 1. Capacity exists off site to serve the development, or 2. A housing and infrastructure phasing plan has been agreed with Thames Water. Where a housing and infrastructure phasing plan is agreed, no occupation shall take place other than in accordance with the agreed housing and infrastructure phasing plan, or 3. All wastewater network upgrades required to accommodate the additional flows from the development have been completed. Reason - Network reinforcement works may be required to accommodate the proposed development. Any reinforcement works identified will be necessary in order to avoid sewage flooding and/or potential pollution incidents. The developer can request information to support the discharge of this condition by visiting the Thames Water website at [thameswater.co.uk/preplanning](http://thameswater.co.uk/preplanning). Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (telephone 0203 577 9998) prior to the planning application approval.

### Water Comments

If you are planning on using mains water for construction purposes, it's important you let Thames Water know before you start using it, to avoid potential fines for improper usage. More information and how to apply can be found online at [thameswater.co.uk/buildingwater](http://thameswater.co.uk/buildingwater).

On the basis of information provided, Thames Water would advise that with regard to water network and water treatment infrastructure capacity, we would not have any objection to the above planning application. Thames Water recommends the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Yours faithfully  
Development Planning Department

Development Planning,  
Thames Water,  
Maple Lodge STW,  
Denham Way,  
Rickmansworth,  
WD3 9SQ  
Tel:020 3577 9998  
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk Visit us online [www.thameswater.co.uk](http://www.thameswater.co.uk) , follow us on twitter [www.twitter.com/thameswater](http://www.twitter.com/thameswater) or find us on [www.facebook.com/thameswater](http://www.facebook.com/thameswater). We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.