

Matthew Swinford

From: Iain Osenton
Sent: 09 January 2020 11:44
To: Planning
Cc: Linda Griffiths; dcregistration
Subject: 19/02614/DISC - CDC Arboriculture

Hi Linda,

Regarding the above referenced DISC. The method statement demonstrates due consideration to trees on site, including recently protected trees.

It will be of interest to hear the outcome of inspection to T194, however I have no further concerns overall.

Kind regards,

Iain Osenton
Arboricultural Officer (South)
Environmental services
Cherwell District Council

 Direct Dial 01295 221708

www.cherwell.gov.uk

Follow us:

Facebook www.facebook.com/Cherwelldistrictcouncil

Twitter @cherwellcouncil



This e-mail (including any attachments) may be confidential and may contain legally privileged information. You should not disclose its contents to any other person. If you are not the intended recipient, please notify the sender immediately.

Whilst the Council has taken every reasonable precaution to minimise the risk of computer software viruses, it cannot accept liability for any damage which you may sustain as a result of such viruses. You should carry out your own virus checks before opening the e-mail(and/or any attachments).

Unless expressly stated otherwise, the contents of this e-mail represent only the views of the sender and does not impose any legal obligation upon the Council or commit the Council to any course of action..