

Consultee Comment for planning application 20/00737/F

Application Number	<input type="text" value="20/00737/F"/>
Location	<input type="text" value="Out Building Adj To Kennels Bicester Road Stratton Audley Bicester OX27 9BT"/>
Proposal	<input type="text" value="Alterations to and conversion of existing outbuildings into 2 new residential units (revised scheme of 19/01312/F)"/>
Case Officer	<input type="text" value="Matthew Chadwick"/>
Organisation	<input type="text" value="Building Control (CDC)"/>
Name	<input type="text"/>
Address	<input type="text" value="Building Control Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="Development would require a building regulations application. Facilities and access for fire fighting vehicles to reflect guidance in Approved Document B5."/>
Received Date	<input type="text" value="08/04/2020 07:58:42"/>
Attachments	