

**District: Cherwell**

**Application No:** 20/00811/OBL-2

**Proposal:** Discharge of Schedule 2 Clause 3.1 of 15/01326/OUT – Car Park Obligations

**Location:** OS Parcels 6741 & 5426 West of Cricket Field North of Wykham Lane Bodicote

---

## **LLFA**

### **Recommendation:**

Comments

### **Detailed comments:**

The Management Plan does not refer to the SuDS Manual C753 for the maintenance of the SuDS features. It should be updated to be in accordance with Section 32 of C753 and also refer to the relevant sections for each SuDS component.

**Officer's Name:** Richard Bennett

**Officer's Title:** Flood Risk Engineer

**Date:** 09 November 2020

---