

Linda Griffiths

From: Judith Ward
Sent: 10 December 2020 15:19
To: Linda Griffiths
Subject: 20/01162/DISC OS Parcel 7400 adj and south of Saltway

Follow Up Flag: Follow up
Flag Status: Flagged

Hi Linda

A few comments:

Detention basin B is 5m deep. Is it expected that there will be standing water in these basins? If so then I think there could be a big safety concern here. If someone fell in no-one would see them. I think we need further information.

The slope to the East side of football pitch is quite steep. I would prefer it to be to a shallower gradient so that it looks more natural.

I have concerns about how the grading of the Gateway landscape mountain fits in with providing a play facility on the top. It is 9m high in places and there will be a requirement to have vehicular access to maintain a play area which hasn't been designed yet

Kind regards
Judith

Judith Ward
Landscape Planning Officer
Cherwell District & South Northants Councils



01295 221711



01295 221878

<mailto:Judith.ward@cherwellandsouthnorthants.gov.uk>

www.cherwell-dc.gov.uk
www.southnorthants.gov.uk

www.facebook.com/cherwelldistrictcouncil
www.facebook.com/southnorthantscouncil

Follow us on Twitter: @Cherwellcouncil
Follow us on Twitter : @SNorthantsC

This e-mail (including any attachments) may be confidential and may contain legally privileged information. You should not disclose its contents to any other person. If you are not the intended recipient, please notify the sender immediately.

Whilst the Council has taken every reasonable precaution to minimise the risk of computer software viruses, it cannot accept liability for any damage which you may sustain as a result of such viruses. You should carry out your own virus checks before opening the e-mail(and/or any attachments).

Unless expressly stated otherwise, the contents of this e-mail represent only the views of the sender and does not impose any legal obligation upon the Council or commit the Council to any course of action..