

District: Cherwell

Application no: 20/02119/DISC

Proposal: Discharge of condition 13 (Flood Risk Assessment) of 18/01430/TWAO

Location: East West Rail Network Phase 2 The Scheme Railway From London Road Bicester To, Station Road, Launton

Lead Local Flood Authority

Recommendation:

No objection

Documents reviewed:

Flood Risk Assessment: CFSA Modelling Report (Westbury Court, culverts C160924 & C160550) 33735_2A-EWR-OXD-XX-RP-DC-000003 Rev B01

Detailed comments:

The report confirms that the flood volumes are contained in the reprofiled ditch network and therefore the CFSA is no longer required.

Land drainage consent has been issued for the ditch reprofiling.

Officer's Name: Richard Bennett

Officer's Title: Flood Risk Engineer

Date: 02 October 2020
