

Consultee Comment for planning application 20/02734/DISC

Application Number	<input type="text" value="20/02734/DISC"/>
Location	<input type="text" value="Heyford Park Camp Road Upper Heyford Bicester OX25 5HD"/>
Proposal	<input type="text" value="Discharge of condition 17 (fire hydrants) of 16/02446/F"/>
Case Officer	<input type="text" value="Andrew Lewis"/>
Organisation	<input type="text" value="Fire Service (Oxfordshire)"/>
Name	<input type="text" value="Jacky Hughes"/>
Address	<input type="text" value="Fire Service HQ Sterling Road Kidlington OX5 2DU"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="Fire hydrants have been marked on the water plan. Before people live in the properties the fire service Hydrant team will need to check the condition, operation and mark up the location of the hydrants."/>
Received Date	<input type="text" value="21/10/2020 17:45:56"/>
Attachments	