

# Consultee Comment for planning application 20/03023/F

|                           |  |
|---------------------------|--|
| <b>Application Number</b> | <input type="text" value="20/03023/F"/>  |
| <b>Location</b>           | <input type="text" value="10 Reid Close Banbury OX16 0SZ"/>  |
| <b>Proposal</b>           | <input type="text" value="Erection of a new 1 bed, two storey dwelling - It forms a side extension to the west of 10 Reid Close"/>   |
| <b>Case Officer</b>       | <input type="text" value="Bob Neville"/>   |
| <b>Organisation</b>       | <input type="text" value="CDC - Land Drainage"/>   |
| <b>Name</b>               | <input type="text" value="Tony Brummell"/>   |
| <b>Address</b>            | <input type="text" value="Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>  |
| <b>Type of Comment</b>    | <input type="text" value="Comment"/>   |
| <b>Type</b>               | <input type="text"/>   |
| <b>Comments</b>           | <input type="text" value="No specific comments but for information a public sewer runs through the rear garden of 10 Reid Close and across the development plot. Depending on circumstances/location to be determined on site, a build-over or near-to agreement may be necessary with Thames Water. Consult them when exact location is known."/> |
| <b>Received Date</b>      | <input type="text" value="25/11/2020 13:16:02"/>   |
| <b>Attachments</b>        |  |