

## Rachel Tibbetts

---

**From:** BCTAdmin@thameswater.co.uk  
**Sent:** 15 December 2020 09:02  
**To:** Planning  
**Subject:** 3rd Party Planning Application - 20/03404/F

Cherwell District Council  
Planning & Development Services  
Bodicote House  
Bodicote, Banbury  
Oxon  
OX15 4AA

Our DTS Ref: 67935  
Your Ref: 20/03404/F

15 December 2020

Dear Sir/Madam

Re: UNIT B, SYMMETRY PARK, MORRELL WAY, AMBROSDEN, OXFORDSHIRE , OX26 6GF

### Waste Comments

Thames Water recognises this catchment is subject to high infiltration flows during certain groundwater conditions. The scale of the proposed development doesn't materially affect the sewer network and as such we have no objection. In the longer term Thames Water, along with other partners, are working on a strategy to reduce groundwater entering the sewer network.

Thames Water recognises this catchment is subject to high infiltration flows during certain groundwater conditions. The developer should liaise with the LLFA to agree an appropriate sustainable surface water strategy following the sequential approach before considering connection to the public sewer network. The scale of the proposed development doesn't materially affect the sewer network and as such we have no objection. In the longer term Thames Water, along with other partners, are working on a strategy to reduce groundwater entering the sewer network.

With regard to SURFACE WATER drainage, Thames Water would advise that if the developer follows the sequential approach to the disposal of surface water we would have no objection. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. Should you require further information please refer to our website. <https://developers.thameswater.co.uk/Developing-a-large-site/Apply-and-pay-for-services/Wastewater-services>

Thames Water would advise that with regard to WASTE WATER NETWORK and SEWAGE TREATMENT WORKS infrastructure capacity, we would not have any objection to the above planning application, based on the information provided.

### Water Comments

If you are planning on using mains water for construction purposes, it's important you let Thames Water know before you start using it, to avoid potential fines for improper usage. More information and how to apply can be found online at [thameswater.co.uk/buildingwater](https://thameswater.co.uk/buildingwater).

There are water mains crossing or close to your development. Thames Water do NOT permit the building over or construction within 3m of water mains. If you're planning significant works near our mains (within 3m) we'll need to

check that your development doesn't reduce capacity, limit repair or maintenance activities during and after construction, or inhibit the services we provide in any other way. The applicant is advised to read our guide working near or diverting our pipes. <https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development/Working-near-or-diverting-our-pipes>

On the basis of information provided, Thames Water would advise that with regard to water network and water treatment infrastructure capacity, we would not have any objection to the above planning application. Thames Water recommends the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Yours faithfully  
Development Planning Department

Development Planning,  
Thames Water,  
Maple Lodge STW,  
Denham Way,  
Rickmansworth,  
WD3 9SQ  
Tel:020 3577 9998  
Email: [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk) Visit us online [www.thameswater.co.uk](http://www.thameswater.co.uk) , follow us on twitter [www.twitter.com/thameswater](http://www.twitter.com/thameswater) or find us on [www.facebook.com/thameswater](http://www.facebook.com/thameswater). We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.