

Rachel Tibbetts

From: planning@cherwell-dc.gov.uk
Sent: 11 January 2021 16:06
To: DC Support
Subject: New comments for application 20/03619/F

New comments have been received for application 20/03619/F at site address: Heyford Park Camp Road Upper Heyford
OX25 5HD

from Tony Brummell land.drainage@cherwell-dc.gov.uk

Address:
Cherwell District Council
Bodicote House
White Post Road
Bodicote
Banbury
OX15 4AA

Comment type:
Object

Comments:
Objection pending further information required.

Clarification needed on attenuation volumes. Global FRA prepared by Peter Brett Associates indicates attenuation volume of 910.7 m³/ha (= 5021 m³ for the development served by this proposal), but only 3892 m³ is being offered. Further calculations are required to justify reduction. (perhaps due to having taken into account in-pipe storage and infiltration from swales?). Suggest Applicant's Drainage Engineer is requested to contact me.

Case Officer:
Andrew Lewis

This e-mail (including any attachments) may be confidential and may contain legally privileged information. You should not disclose its contents to any other person. If you are not the intended recipient, please notify the sender immediately.

Whilst the Council has taken every reasonable precaution to minimise the risk of computer software viruses, it cannot accept liability for any damage which you may sustain as a result of such viruses. You should carry out your own virus checks before opening the e-mail(and/or any attachments).

Unless expressly stated otherwise, the contents of this e-mail represent only the views of the sender and does not impose any legal obligation upon the Council or commit the Council to any course of action..