

Consultee Comment for planning application 21/00026/F

Application Number	<input type="text" value="21/00026/F"/>
Location	<input type="text" value="13 Blackwood Place Bodicote OX15 4BD"/>
Proposal	<input type="text" value="Erection of dwelling house, garage and associated vehicular access off Oxford Road A4260 - re-submission of 20/02152/F"/>
Case Officer	<input type="text" value="Bob Neville"/>
Organisation	<input type="text" value="CDC - Land Drainage"/>
Name	<input type="text" value="Tony Brummell"/>
Address	<input type="text" value="Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input "build="" agreement="" be="" build-over"="" may="" near-to"="" or="" required."="" thames="" type="text" value="No comments on land drainage. However, we believe a public foul sewer crosses the front of the site which will need to be protected/accommodated. Suggest the applicant confirms the location of this sewer before proceeding with any works. A " water="" with=""/>
Received Date	<input type="text" value="12/01/2021 12:20:24"/>
Attachments	