

Lynne Baldwin

From: Neil Whitton
Sent: 15 January 2021 09:15
To: Bob Neville
Cc: DC Support
Subject: 21/00026/F - 13 Blackwood Place Bodicote OX15 4BD

Environmental Protection has the following response to this application as presented:

Noise: Prior to the development commencing a report should be provided and approved in writing by the local planning authority that shows that all habitable rooms within the dwelling will achieve the noise levels specified in BS8233:2014 (Guidance on sound insulation and noise reduction for buildings) for indoor and external noise levels. Thereafter, and prior to the first occupation of the dwellings affected by this condition, the dwellings affected by this condition, the dwellings shall be shall be insulated and maintained in accordance with the approved details

Contaminated Land: If, during development, contamination not previously identified is found to be present at the site, no further development shall be carried out until full details of a remediation strategy detailing how the unsuspected contamination shall be dealt with has been submitted to and approved in writing by the Local Planning Authority. Thereafter the remediation strategy shall be carried out in accordance with the approved details.

Air Quality: The dwelling(s) hereby permitted shall not be occupied until it/they has/have been provided with a system of electrical vehicle charging to serve that dwelling.

Reason – To comply with policies SLE 4, ESD 1, ESD 3 and ESD 5 of the adopted Cherwell Local Plan 2011-2031 Part 1 and to maximise opportunities for sustainable transport modes in accordance with paragraph 110(e) of the National Planning Policy Framework

Odour: No comments

Light: No comments

If you wish to deviate from the suggested conditions then this should be discussed with the officer making these comments to ensure the meaning of the condition remains and that the condition is enforceable and reasonable.

NB: Please note my new working pattern below, I will only respond on the days appropriate to the email content
Mon – Weds: Environmental Protection, Thurs – Fri: Health Protection and Compliance

Kind Regards

Neil Whitton BSC, MCIEH
Environmental Health Officer
Environmental Health and Licensing
Cherwell District Council
Tel - 01295 221623
Email - Neil.Whitton@cherwell-dc.gov.uk

<http://www.cherwell.gov.uk/>
Find us on Facebook www.facebook.com/cherwelldistrictcouncil

Follow us on Twitter @Cherwellcouncil

This e-mail (including any attachments) may be confidential and may contain legally privileged information. You should not disclose its contents to any other person. If you are not the intended recipient, please notify the sender immediately.

Whilst the Council has taken every reasonable precaution to minimise the risk of computer software viruses, it cannot accept liability for any damage which you may sustain as a result of such viruses. You should carry out your own virus checks before opening the e-mail(and/or any attachments).

Unless expressly stated otherwise, the contents of this e-mail represent only the views of the sender and does not impose any legal obligation upon the Council or commit the Council to any course of action..