

# Consultee Comment for planning application 21/00026/F

<b>Application Number</b>	<input type="text" value="21/00026/F"/>
<b>Location</b>	<input type="text" value="13 Blackwood Place Bodicote OX15 4BD"/>
<b>Proposal</b>	<input type="text" value="Erection of dwelling house, garage and associated vehicular access off Oxford Road A4260 - re-submission of 20/02152/F"/>
<b>Case Officer</b>	<input type="text" value="Bob Neville"/>
<b>Organisation</b>	<input type="text" value="Building Control (CDC)"/>
<b>Name</b>	<input type="text"/>
<b>Address</b>	<input type="text" value="Building Control Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
<b>Type of Comment</b>	<input type="text" value="Comment"/>
<b>Type</b>	<input type="text"/>
<b>Comments</b>	<input type="text" value="Building control application required. Protected stairway required or provide escape windows to each bedroom."/>
<b>Received Date</b>	<input type="text" value="22/01/2021 16:57:32"/>
<b>Attachments</b>	