

# Consultee Comment for planning application 21/00104/F

<b>Application Number</b>	21/00104/F
<b>Location</b>	OS Parcels 3309 And 4319 Adjoining And North Of Milton Road Adderbury
<b>Proposal</b>	Variation of Condition 2 (plans) of 19/02796/F - amend the drawing numbers, to reflect the proposed building (reduced in size).
<b>Case Officer</b>	Matthew Chadwick
<b>Organisation</b>	CDC - Land Drainage
<b>Name</b>	Tony Brummell
<b>Address</b>	Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA
<b>Type of Comment</b>	Comment
<b>Type</b>	
<b>Comments</b>	No comments in principle. However, if there are any increases in impermeable area resulting from this application, they must be reflected in a revised surface water drainage to be submitted for approval prior to any development commencing.
<b>Received Date</b>	09/02/2021 13:31:48
<b>Attachments</b>	