

Application no: 21/00479/DISC-2

Location: Stone Pits Hempton Road Deddington

Local Lead Flood Authority

Recommendation:

Objection

Key issues:

Microdrainage calculations:

- do not show the impermeable area taken into account.
- Submitted data is for return period of 1 in 30 years. LLFA require full microdrainage calculations for all events up to and including the 1 in 100 year plus climate change

Infiltration Testing results:

- Location plan of trial pits are nowhere to be found.

Drawings:

- no cross section details have been submitted.

Other:

- Confirmation that infiltration is not proposed in contaminated land has not been proven.

Officer's Name: Sujeenthan Jeevarangan

Officer's Title: LLFA Planning Engineer

Date: 28/07/2021