

**From:** Bawar, Nagina - Oxfordshire County Council  
**Sent:** 23 February 2022 18:46  
**To:** Sarah Greenall; Planning Consultations - E&E  
**Cc:** Alex Chrusciak ; Jane Law; Manku, Amrik - Communities; LLFA Planning Service  
**Subject:** FW: 21/00517/F - Motorcross, Wroxton - High Profile case with OCC LFA objection  
**Importance:** High

Hi Sarah,

I hope you're well.

I have now reviewed all the relevant document regarding LLFA matters and have the following comments:

We have no objection to this app.

There are no works being carried out to increase impermeable areas to the site. The Flood Risk Assessment (Lidar-Logic, ref: Report LL071, February 2021) shows that the existing drainage system on site will be retained and ongoing maintenance is carried out throughout the year by Wroxton Motocross. Therefore, as long as the maintenance regime as per the FRA is carried out, we have no objection to this app.

Kind Regards

**Nagina Bawar**  
Senior LLFA Engineer

Oxfordshire County Council | County Hall | New Road | Oxford | OX1 1ND