

Consultee Comment for planning application 21/00922/OUT

Application Number	21/00922/OUT
Location	Land West Of Foxden Way Great Bourton OX17 1QY
Proposal	OUTLINE Planning Application for up to 9 entry-level affordable houses - all matters reserved save for access
Case Officer	James Kirkham
Organisation	CDC - Land Drainage
Name	Tony Brummell
Address	Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA
Type of Comment	Comment
Type	
Comments	No comments in principle. Site is not shown to be at risk of flooding from any source. There is no surface water sewerage at this location so surface water will have to be discharged to soakaways. Robust BRE365 tests should be undertaken to ensure that soakaways are of appropriate sizes, and that the surface water is contained within the site.
Received Date	16/04/2021 10:33:23
Attachments	