

Consultee Comment for planning application 21/00922/OUT

Application Number	<input type="text" value="21/00922/OUT"/>
Location	<input type="text" value="Land West Of Foxden Way Great Bourton OX17 1QY"/>
Proposal	<input type="text" value="OUTLINE Planning Application with all matters reserved save for access for up to 9 First Homes"/>
Case Officer	<input type="text" value="James Kirkham"/>
Organisation	<input type="text" value="CDC - Land Drainage"/>
Name	<input type="text" value="Tony Brummell"/>
Address	<input type="text" value="Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="Drainage/Flood Risk: No comments in principle on this application. The surface water drainage strategy presented by MEC Consulting Development Engineers has been accepted on the basis of an attenuation discharge to an existing ditch in Foxden Way as the ground at the site is not sufficiently porous to allow containment of surface water on the site through soakaways."/>
Received Date	<input type="text" value="15/02/2022 15:15:34"/>
Attachments	