

# Consultee Comment for planning application 21/01123/F

<b>Application Number</b>	<input type="text" value="21/01123/F"/>
<b>Location</b>	<input type="text" value="Hatch End Old Poultry Farm Steeple Aston Road Middle Aston Bicester OX25 5QL"/>
<b>Proposal</b>	<input type="text" value="Demolition of existing buildings. Construction of replacement business units and associated external works. (Re-submission of 20/01127/F)"/>
<b>Case Officer</b>	<input type="text" value="James Kirkham"/>
<b>Organisation</b>	<input type="text" value="CDC - Land Drainage"/>
<b>Name</b>	<input type="text" value="Tony Brummell"/>
<b>Address</b>	<input type="text" value="Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
<b>Type of Comment</b>	<input type="text" value="Comment"/>
<b>Type</b>	<input type="text"/>
<b>Comments</b>	<input type="text" value="No comments on land drainage. No mains sewerage is available so development will have to incorporate a private sewage disposal plant for which an Environmental Permit may be needed."/>
<b>Received Date</b>	<input type="text" value="19/04/2021 11:43:24"/>
<b>Attachments</b>	