

# Consultee Comment for planning application 21/01135/F

<b>Application Number</b>	<input type="text" value="21/01135/F"/>
<b>Location</b>	<input type="text" value="4 Woodcote Road Caversfield OX27 8TZ"/>
<b>Proposal</b>	<input type="text" value="Two storey side extension and single storey rear extensions"/>
<b>Case Officer</b>	<input type="text" value="Emma Whitley"/>
<b>Organisation</b>	<input type="text" value="Building Control (CDC)"/>
<b>Name</b>	<input type="text"/>
<b>Address</b>	<input type="text" value="Building Control Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
<b>Type of Comment</b>	<input type="text" value="Comment"/>
<b>Type</b>	<input type="text"/>
<b>Comments</b>	<input type="text" value="Development requires a building control application. Escape windows required in home office in line with Approved document B."/>
<b>Received Date</b>	<input type="text" value="02/06/2021 13:42:40"/>
<b>Attachments</b>	