

Consultee Comment for planning application 21/01346/F

Application Number	<input type="text" value="21/01346/F"/>
Location	<input type="text" value="1 Montgomery Road Caversfield OX27 8FG"/>
Proposal	<input type="text" value="Two storey side extension and single storey rear extension."/>
Case Officer	<input type="text" value="John Cosgrove"/>
Organisation	<input type="text" value="Building Control (CDC)"/>
Name	<input type="text"/>
Address	<input type="text" value="Building Control Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="The proposed works will require an application for Building Regulation approval. The newly created bedrooms at first floor will require escape windows."/>
Received Date	<input type="text" value="01/06/2021 16:58:03"/>
Attachments	