

Consultee Comment for planning application 21/01535/F

Application Number	<input type="text" value="21/01535/F"/>
Location	<input type="text" value="Lane Head Main Street Sibford Gower OX15 5RT"/>
Proposal	<input type="text" value="Demolish existing garage for replacement with oak framed carport and roof alterations to create first floor over existing ancillary outbuilding to create pool and annexe accommodation"/>
Case Officer	<input type="text" value="Lewis Knox"/>
Organisation	<input type="text" value="Building Control (CDC)"/>
Name	<input type="text"/>
Address	<input type="text" value="Building Control Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="The proposed first floor accommodation over the Annexe and the Carport will require means-of-escape rooflights."/>
Received Date	<input type="text" value="13/08/2021 17:24:50"/>
Attachments	