

Consultee Comment for planning application 21/01624/F

Application Number	21/01624/F
Location	The White House Main Street Wendlebury OX25 2PW
Proposal	Rear extension over one and two storeys.
Case Officer	John Cosgrove
Organisation	CDC - Land Drainage
Name	Tony Brummell
Address	Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA
Type of Comment	Comment
Type	
Comments	There is a high risk of surface water flooding and a medium risk of fluvial flooding in Main Street at the front of the property. No objections in principle but advise applicant to ensure that finished floor level is above maximum flood level and the surface water flood risk is mitigated.
Received Date	20/05/2021 11:36:29
Attachments	