

Application no: 21/02180/REM

Location: OS Parcel 9507 South Of 26 And Adjoining, Fewcott Road, Fritwell

Local Lead Flood Authority

Recommendation:

Objection

Detailed comments:

There are no details of impermeable areas associated with the development mentioned anywhere in the report. A catchment drawing showing the impermeable areas must be submitted. This drawing must match the information used in the hydraulic modelling.

Officer's Name: Sujeenthan Jeevarangan

Officer's Title: LLFA Planning Engineer

Date: 31/08/2021