

Application no: 21/02376/DISC

Location: E P Barrus Ltd, Launton Road, Bicester, OX26 4UR

Local Lead Flood Authority

Recommendation:

Objection to Discharge of Condition 6

Detailed comments:

The discharge of condition 6 has been objected on the following basis;

Insufficient details were provided to demonstrate the SuDS design for the proposed development. It is therefore not possible to undertake a technical assessment of the proposal and ascertain whether a sustainable surface water drainage strategy can be delivered on site.

Insufficient information was provided in the Flood Exceedance Layout and surface water drainage layouts;

Drainage calculation for the 1 in 1 year, 1 in 30 year and 1 in 100 year + 40% climate change were not provided to confirm the required sizes for SuDS.

No details provided of the future maintenance and management of the site SuDS features.

A detailed surface water management strategy report must be submitted in accordance with the [Local Standards and Guidance for Surface Water Drainage on Major Development in Oxfordshire](#)

In line with this guidance, runoff must be managed at source (i.e. close to where it falls) with residual flows then conveyed downstream to further storage or treatment components, where required. The proposed drainage should mimic the existing drainage regime of the site as much as possible

Proposed development needs a water quality assessment in accordance with Section 4 and Section 26 of SuDS Manual.

Proposed development must meet local standards, L19, "At least one surface feature should be deployed within the drainage system for water quality purposes, or more features for runoff which may contain higher levels of pollutants in accordance with the CIRIA SuDS Manual C753. Only if surface features are demonstrated as not viable, then approved proprietary engineered pollution control features such as vortex separators, serviceable/ replaceable filter screens, or pollution interceptors may be used"

The applicant is required to provide a Surface Water Management Strategy in accordance with the following guidance:

The [Sustainable Drainage Systems \(SuDS\) Policy](#), which came into force on the 6th April 2015 requires the use of sustainable drainage systems to manage runoff on all applications relating to major development. As well as dealing with surface water runoff, they are required to provide water quality, biodiversity and amenity benefits in line with National Guidance. The [Sustainable Drainage Systems \(SuDS\) Policy](#) also implemented changes to the [Town and Country Planning \(Development Management Procedure\) \(England\) Order 2010](#) to make the Lead Local Flood Authority (LLFA) a statutory Consultee for Major Applications in relation to surface water drainage. This was implemented in place of the SuDS Approval Bodies (SAB's) proposed in Schedule 3 of the Flood and Water Management Act 2010.

All full and outline planning applications for Major Development must be submitted with a Surface Water Management Strategy. A site-specific Flood Risk Assessment (FRA) is also required for developments of 1 hectare or greater in Flood Zone 1; all developments in Flood Zones 2 and 3 or in an area within Flood Zone 1 notified as having critical drainage problems; and where development or a change of use to a more vulnerable class may be subject to other sources of flooding.

Further information on flood risk in Oxfordshire, which includes access to view the existing fluvial and surface water flood maps, can be found on the [Oxfordshire flood tool kit](#) website. The site also includes specific flood risk information for developers and Planners.

The [National Planning Policy Framework](#) (NPPF), which was updated in February 2019 provides specific principles on flood risk (Section 14, from page 45). [National Planning Practice Guidance](#) (NPPG) provides further advice to ensure new development will come forward in line with the NPPF.

Paragraph 155 states; "Inappropriate development in areas at risk of flooding should be avoided by directing development away from areas at highest risk (whether existing or future). Where development is necessary in such areas, the development should be made safe for its lifetime without increasing flood risk elsewhere."

As stated in Paragraph 158 of the NPPF, we will expect a sequential approach to be used in areas known to be at risk now or in the future from any form of flooding.

The [Non-statutory technical Standards for sustainable drainage systems](#) were produced to provide initial principles to ensure developments provide SuDS in line with the NPPF and NPPG. Oxfordshire County Council have published the "[Local Standards and Guidance for Surface Water Drainage on Major Development in Oxfordshire](#)" to assist developers in the design of all surface water drainage systems, and to support Local Planning Authorities in considering drainage proposals for new development in Oxfordshire. The guide sets out the standards that we apply in assessing all surface water drainage proposals to ensure they are in line with National legislation and guidance, as well as local requirements.

The SuDS philosophy and concepts within the Oxfordshire guidance are based upon and derived from the CIRIA [SuDS Manual \(C753\)](#), and we expect all development to come forward in line with these principles.

In line with the above guidance, surface water management must be considered from the beginning of the development planning process and throughout – influencing site layout and design. The proposed drainage solution should not be limited by the proposed site layout and design.

Wherever possible, runoff must be managed at source (i.e. close to where it falls) with residual flows then conveyed downstream to further storage or treatment components, where required. The proposed drainage should mimic the existing drainage regime of the site. Therefore, we will expect existing drainage features on the site to be retained and they should be utilised and enhanced wherever possible.

Although we acknowledge it will be hard to determine all the detail of source control attenuation and conveyance features at concept stage, we will expect the Surface Water Management Strategy to set parameters for each parcel/phase to ensure these are included when these parcels/phases come forward. Space must be made for shallow conveyance features throughout the site and by also retaining existing drainage features and flood flow routes, this will ensure that the existing drainage regime is maintained, and flood risk can be managed appropriately.

By the end of the Concept Stage evaluation and initial design/investigations Flows and Volumes should be known. Therefore, we ask that the following Pro-Forma is completed and returned as soon as possible:

[Drainage Pro-Forma](#)

Officer's Name: Sujeenthan Jeevarangan
Officer's Title: LLFA Planning Engineer
Date: 17/08/2021