

Consultee Comment for planning application 21/02417/F

Application Number	<input type="text" value="21/02417/F"/>
Location	<input type="text" value="Land Adjoining And West Of Stonecroft House Clifton Road Deddington"/>
Proposal	<input type="text" value="Variation of Condition 2 (plans) of 20/03467/F - Erection of 7 one and two storey age restricted dwellings for older people (60+ years), formation of means of access, and associated landscaping and infrastructure"/>
Case Officer	<input type="text" value="James Kirkham"/>
Organisation	<input type="text" value="CDC - Land Drainage"/>
Name	<input type="text" value="Tony Brummell"/>
Address	<input type="text" value="Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="No comments on flood risk. There are no surface water sewers available to the site and no evidence of any ditches or watercourses to which surface water from the site can be drained. Therefore, the site will depend on soakaways to be designed and constructed in accordance with BRE 365."/>
Received Date	<input type="text" value="28/07/2021 11:37:25"/>
Attachments	