

Consultee Comment for planning application 21/02496/DISC

Application Number	21/02496/DISC
Location	Land To The South And Adj To South Side Steeple Aston
Proposal	Discharge of Conditions 5 (surface water drainage details), 8 (full specification details of parking and manoeuvring areas) and 9 (full specification details of accesses, driveways and turning areas) of 19/02948/F
Case Officer	Nathanael Stock
Organisation	CDC - Land Drainage
Name	Tony Brummell
Address	Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA
Type of Comment	Object
Type	
Comments	Surface Water Drainage: Refer to my consultation response dated 31/07/2021. The applicant has not provided any further information to demonstrate that soakage is an acceptable and practically achievable means of surface water drainage particularly on the western part of the site. The applicant to provide calculations of proposed soakaway sizes in accordance with Building Regulations Approved Document H paragraphs 3.23 to 3.30.
Received Date	12/01/2022 16:43:42
Attachments	