

Consultee Comment for planning application 21/02638/F

Application Number	<input type="text" value="21/02638/F"/>
Location	<input type="text" value="13 Springfield Road Caversfield Bicester OX27 8TT"/>
Proposal	<input type="text" value="Erection of single storey extension and front porch with the addition of new rooflights."/>
Case Officer	<input type="text" value="John Cosgrove"/>
Organisation	<input type="text" value="Building Control (CDC)"/>
Name	<input type="text"/>
Address	<input type="text" value="Building Control Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="A building control application will be required before work commences on site. An emergency escape window or door must be provided for the new office off the lounge."/>
Received Date	<input type="text" value="10/09/2021 12:07:56"/>
Attachments	