

From: Neil Whitton
Sent: 21 June 2022 12:17
To: Caroline Ford
Cc: DC Support <DC.Support@cherwell-dc.gov.uk>
Subject: 21/03177/F - Axis J9 Phase 3, Howes Lane, Bicester, Oxfordshire

Dear Caroline,

Having read the updated AQ report for this application I am satisfied with its methodology and findings. I would like to see the following condition placed on any permission granted:

The development(s) hereby permitted shall not be occupied until it has been provided with a system of electrical vehicle charging to serve those development(s) In addition ducting should be in place to allow for the easy expansion of the EV charging system as demand increases towards the planned phase out of ICE vehicles (ideally ducting should be provided to every parking space to future proof the development).

Kind Regards

Neil Whitton BSC, MCIEH
Environmental Health Officer
Environmental Health and Licensing
Cherwell District Council