

From: [BCTAdmin@thameswater.co.uk](mailto:BCTAdmin@thameswater.co.uk)  
Sent: 28 October 2021 08:36  
To: Planning  
Subject: 3rd Party Planning Application - 21/03267/OUT

CAUTION: This email originated from outside of the Council. Do not click links or open attachments unless you recognise the sender and know the content is safe.

Cherwell District Council  
Planning & Development Services  
Bodicote House  
Bodicote, Banbury  
Oxon  
OX15 4AA

Our DTS Ref: 70035  
Your Ref: 21/03267/OUT

28 October 2021

Dear Sir/Madam

Re: OS Parcel 0006 South East Of Baynards House , Adjoining A43 , Baynards Green, BICESTER, Oxfordshire, OX27

#### Waste Comments

With regard to sewerage and sewage treatment, this comes within the area covered by Anglian Water PLC. For your information the address to write to is Anglian Water PLC, Anglian House, Ambury Road, Huntingdon, Cambs PE18 6NZ [Tel:- \(01480\) 433400](tel:01480433400)

#### Water Comments

Following initial investigations, Thames Water has identified an inability of the existing water network infrastructure to accommodate the needs of this development proposal. Thames Water have contacted the developer in an attempt to agree a position on water networks but have been unable to do so in the time available and as such Thames Water request that the following condition be added to any planning permission. No development shall be occupied until confirmation has been provided that either:- all water network upgrades required to accommodate the additional flows to serve the development have been completed; or - a development and infrastructure phasing plan has been agreed with Thames Water to allow development to be occupied. Where a development and infrastructure phasing plan is agreed no occupation shall take place other than in accordance with the agreed development and infrastructure phasing plan. Reason - The development may lead to no / low water pressure and network reinforcement works are anticipated to be necessary to ensure that sufficient capacity is made available to accommodate additional demand anticipated from the new development” The developer can request information to support the discharge of this condition by visiting the Thames Water website at [thameswater.co.uk/preplanning](http://thameswater.co.uk/preplanning). Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (telephone 0203 577 9998) prior to the planning application approval.

Yours faithfully  
Development Planning Department

Development Planning,  
Thames Water,  
Maple Lodge STW,  
Denham Way,  
Rickmansworth,  
WD3 9SQ