

From: BCTAdmin@thameswater.co.uk <BCTAdmin@thameswater.co.uk>
Sent: 27 April 2022 10:16
To: Robin Forrester <Robin.Forrester@cherwell-dc.gov.uk>
Subject: 3rd Party Planning Application - 21/03268/OUT - UPDATED 27 APR 22

CAUTION: This email originated from outside of the Council. Do not click links or open attachments unless you recognise the sender and know the content is safe.

Cherwell District Council
Planning & Development Services
22
Bodicote House
Bodicote, Banbury
Oxon
OX15 4AA

Our DTS Ref: 70035
Your Ref: 21/03268/OUT - UPDATED 27 APR

27 April 2022

Dear Sir/Madam

Re: OS Parcel 2636 NW Of Baynards House , Adjoining A43 , Baynards Green, BICESTER, Oxfordshire, OX27

Waste Comments

With regard to sewerage and sewage treatment, this comes within the area covered by Anglian Water PLC. For your information the address to write to is Anglian Water PLC, Anglian House, Ambury Road, Huntingdon, Cambs PE18 6NZ [Tel:- \(01480\) 433400](tel:01480433400)

Water Comments

Thames Water are currently working with the developer of application 21/03268/OUT to identify and deliver the off site water infrastructure needs to serve the development. Thames Water have identified that some capacity exists within the water network but beyond that upgrades to the water network will be required. Works are on going to understand this in more detail and as such Thames Water feel it would be prudent for an appropriately worded planning condition to be attached to any approval to ensure development doesn't outpace the delivery of essential infrastructure. There shall be no occupation until confirmation has been provided that either:- all water network upgrades required to accommodate the additional demand to serve the development have been completed; or- a development and infrastructure phasing plan has been agreed with Thames Water to allow additional development to be occupied. Where a development and infrastructure phasing plan is agreed no occupation of the additional development shall take place other than in accordance with the agreed development and infrastructure phasing plan. Reason - The development may lead to low / no water pressures and network reinforcement works are anticipated to be necessary to ensure that sufficient capacity is made available to accommodate additional demand anticipated from the new development. Any necessary reinforcement works will be necessary in order to avoid low / no water pressure issues. Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (telephone 0203 577 9998) prior to the planning application approval.

There are water mains crossing or close to your development. Thames Water do NOT permit the building over or construction within 3m of water mains. If you're planning significant works near our mains (within 3m) we'll need to check that your development doesn't reduce capacity, limit repair or maintenance activities during and after construction, or inhibit the services we provide in any other way. The applicant is advised to read our guide working near or diverting our pipes.

<https://www.thameswater.co.uk/developers/larger-scale-developments/planning-your-development/working-near-our-pipes>

Yours faithfully
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ
[Tel:020 3577 9998](tel:02035779998)
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk Visit us online www.thameswater.co.uk , follow us on twitter www.twitter.com/thameswater or find us on www.facebook.com/thameswater. We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.