

Consultee Comment for planning application 21/03644/OUT

Application Number	21/03644/OUT
Location	OS Parcel 6372 South East Of Milestone Farm Broughton Road Banbury
Proposal	Erection of up to 49 dwellings, associated open space, sustainable urban drainage systems, and access from Balmoral Avenue
Case Officer	David Lowin
Organisation	CDC - Land Drainage
Name	Tony Brummell
Address	Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA
Type of Comment	Comment
Type	
Comments	This is a Major Development application so substantive comments will be provided by the LLFA. The surface water drainage strategy should be considered alongside that of the surface water drainage strategy for the site (also under determination) immediately to the south which largely abuts Broughton Road. The Flood Risk Assessment has not considered the possible escape of water from the enclosed Thames Water reservoir (contact tank) close to the north-east of the site.
Received Date	29/10/2021 11:39:13
Attachments	