

Consultee Comment for planning application 21/04289/OUT

Application Number	<input type="text" value="21/04289/OUT"/>
Location	<input type="text" value="OS Parcel 1570 Adjoining And West Of Chilgrove Drive And Adjoining And North Of Camp Road Heyford Park"/>
Proposal	<input type="text" value="Outline planning application for the erection of up to 230 dwellings, creation of new vehicular access from Camp Road and all associated works with all matters reserved apart from Access"/>
Case Officer	<input type="text" value="Andrew Lewis"/>
Organisation	<input type="text" value="CDC - Land Drainage"/>
Name	<input type="text" value="Tony Brummell"/>
Address	<input type="text" value="Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="Flood Risk/Drainage:
The site contains an upstream reach of the Gallos Brook where the flood plain has not yet been modelled or mapped. The extent of the flood plain, if any, will be needed to accurately inform the limits of the developable areas. It is also noted that areas of surface water flood risk including ponds lie adjacent to the Brook. This risk will need to be mitigated if any such areas lie outside the fluvial flood plain."/>
Received Date	<input type="text" value="03/08/2022 16:33:14"/>
Attachments	