

Consultee Comment for planning application 22/00102/F

Application Number	<input type="text" value="22/00102/F"/>
Location	<input type="text" value="Littlebury Backside Lane Sibford Gower OX15 5RS"/>
Proposal	<input type="text" value="Conversion of loft to habitable accommodation and associated alterations, including rooflights and dormer window to west. New bay window to west at ground floor. (Submission predominantly a renewal of 17/01587/F)"/>
Case Officer	<input type="text" value="Lewis Knox"/>
Organisation	<input type="text" value="Building Control (CDC)"/>
Name	<input type="text" value=""/>
Address	<input type="text" value="Building Control Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text" value=""/>
Comments	<input type="text" value="A Building Regulations application will be required. Bedrooms will require windows suitable for means of escape in case of fire."/>
Received Date	<input type="text" value="15/02/2022 13:43:21"/>
Attachments	