

From: BCTAdmin@thameswater.co.uk
Sent: 24 March 2022 10:31
To: Planning
Subject: 3rd Party Planning Application - 22/00747/OUT

CAUTION: This email originated from outside of the Council. Do not click links or open attachments unless you recognise the sender and know the content is safe.

Cherwell District Council
Planning & Development Services
Bodicote House
Bodicote, Banbury
Oxon
OX15 4AA

Our DTS Ref: 55031
Your Ref: 22/00747/OUT

24 March 2022

Dear Sir/Madam

Re: LAND AT, BICESTER ROAD, KIDLINGTON, KIDLINGTON, OXFORDSHIRE , OX5 2LL

Waste Comments

With the information provided, Thames Water has been unable to determine the Foul water infrastructure needs of this application. Thames Water has contacted the developer in an attempt to obtain this information and agree a position for FOUL WATER drainage, but have been unable to do so in the time available and as such, Thames Water request that the following condition be added to any planning permission. "No development shall be occupied until confirmation has been provided that either:- 1. Foul water Capacity exists off site to serve the development, or 2. A development and infrastructure phasing plan has been agreed with the Local Authority in consultation with Thames Water. Where a development and infrastructure phasing plan is agreed, no occupation shall take place other than in accordance with the agreed development and infrastructure phasing plan, or 3. All Foul water network upgrades required to accommodate the additional flows from the development have been completed. Reason - Network reinforcement works may be required to accommodate the proposed development. Any reinforcement works identified will be necessary in order to avoid sewage flooding and/or potential pollution incidents. The developer can request information to support the discharge of this condition by visiting the Thames Water website at thameswater.co.uk/preplanning. Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (telephone 0203 577 9998) prior to the planning application approval.

The application indicates that SURFACE WATER will NOT be discharged to the public network and as such Thames Water has no objection, however approval should be sought from the Lead Local Flood Authority. Should the applicant subsequently seek a connection to discharge surface water into the public network in the future then we would consider this to be a material change to the proposal, which would require an amendment to the application at which point we would need to review our position.

Water Comments

Following initial investigations, Thames Water has identified an inability of the existing water network infrastructure to accommodate the needs of this development proposal. Thames Water have contacted the developer in an attempt to agree a position on water networks but have been unable to do so in the time available and as such Thames Water request that the following condition be added to any planning permission. No development shall be occupied until confirmation has been provided that either:- all water network upgrades required to accommodate the additional demand to serve the development have been completed; or - a development and infrastructure phasing plan has been agreed with Thames Water to allow development to be occupied. Where a development and infrastructure phasing plan is agreed no occupation shall take place other than in accordance with the agreed development and infrastructure phasing plan. Reason - The development may lead to no / low water pressure and network reinforcement works are anticipated to be necessary to ensure that sufficient capacity is made available to accommodate additional demand anticipated from the new development" The developer can request information to support the discharge of this condition by visiting the Thames Water website at thameswater.co.uk/preplanning. Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (telephone 0203 577 9998) prior to the planning application approval.

Supplementary Comments

Thames Water advise that a drainage strategy should make clear the location of where the development's foul drainage will be connected to the public sewer either pumped or gravity to make a full capacity assessment.

Yours faithfully
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ