

Consultee Comment for planning application 22/00778/DISC

Application Number	22/00778/DISC
Location	Land Adjoining And West Of Stonecroft House Clifton Road Deddington
Proposal	Discharge of Conditions 3 (proposed parking turning, loading, and unloading provision for vehicles to be accommodated within the site including details of the proposed surfacing and drainage of the provision), 11 (Biodiversity) and 12 (AMS) of 21/02417/F
Case Officer	James Kirkham
Organisation	CDC - Land Drainage
Name	Tony Brummell
Address	Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA
Type of Comment	Comment
Type	
Comments	Drainage: Please request the applicant to provide details of the BRE 365 tests carried out on the site and the resultant Micro-Drainage calculations to verify the size of the proposed soakaway.
Received Date	14/04/2022 10:26:40
Attachments	