

**From:** Baker, Keith <[Keith.Baker@severntrent.co.uk](mailto:Keith.Baker@severntrent.co.uk)>

**Date:** Tuesday, 2 November 2021 at 08:38

**To:** Jacob Cronin <[Jacob.Cronin@jnpgroup.co.uk](mailto:Jacob.Cronin@jnpgroup.co.uk)>

**Subject:** RE: DE: 8469031 - Off Hook Norton Road, Sibford Ferris, Oxfordshire [Filed 02 Nov 2021 08:39]

ST Classification: OFFICIAL PERSONAL

Hi Jacob,

The modelling was completed 3 weeks ago, it was delayed being completed by the modelling contractors due to workloads over the summer months. The results are as follows:

Flooding Impact: LOW

Pollution Impact: N/A

Operational Impact: N/A

The above means there is sufficient capacity within the public sewer network in Sibford Ferris. However, I had to check this out with our sewage treatment colleagues for the capacity at Sibford Gower STW and whether they can accept a pumped discharge of 5 l/sec, to which I am still awaiting a response. I will chase this to hopefully get a response as soon as possible and then feed that back to you.

Kind regards,

Keith Baker  
Asset Protection  
Asset Strategy and Planning  
Chief Engineer